

CCR REPORT 2022

Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The Aquifer

Source water assessment and its availability

No source water assessment has been completed

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Monthly city council meetings

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rigby city of is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Additional Information for Arsenic

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Inorganic Contaminants								

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Arsenic (ppb)	0	10	3	NA	3	2022	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.071	NA	.071	2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	100	2	NA	2	2022	No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	.349	NA	.349	2022	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	2.41	NA	2.41	2022	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Radioactive Contaminants								
Radium (combined 226/228) (pCi/L)	0	5	.083	NA	.083	2022	No	Erosion of natural deposits
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	.064	January to June 2022		No	Corrosion of household plumbing systems; Erosion of natural deposits	
Copper - action level at consumer taps (ppm)	1.3	1.3	0	July to December 2022		No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	2	January to June 2022		No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	0	July to December 2022		No	Corrosion of household plumbing systems; Erosion of natural deposits	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: JD Erickson
 Address: 158 W.Fremont
 Rigby, Id 83442
 Phone: 2087458111

Chemical And Radiological Sampling History

PWS Number: ID7260032
 PWS Name: RIGBY CITY OF
 Total Records: 576

A PWS is only required to report the most recent detections of any contaminant at each representative sampling location. For example, if nitrate is detected in a sample collected at Well X in 2021, but is not detected at Well X in 2022, then the system is not required to report nitrate for Well X in the 2022 CCR. **Note:** If a contaminant (e.g., nitrate) is listed with a "Y" (meaning "Yes") in the "non-detect" column, this means that sampling results showed a "non-detect" - that is to say, nitrate was not detected.

Required Language. If a system reports a detection, the system must give the major sources of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Major Sources in Drinking Water" column and place it in your CCR. If the system exceeds the MCL (maximum contaminant level) value of a contaminant, the system must show the potential health effects of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Health Effects Language" column and place it in your CCR.

Abbreviations used below:

MG/L (mg/L) = milligrams per liter (mg/L = ppm in Appendix A)
 UG/L (µg/L) = micrograms per liter (µg/L = ppb in Appendix A)
 PIC/L (pCi/L) = picocuries per liter

Contaminant	Date Collected	Facility	Non Detect?	Detected Level	Units	CCR Units
1,1,1-TRICHLOROETHANE	01/18/2023	WELL #5	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	01/18/2023	WELL #5	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	11/29/2022	WELL #2	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	11/29/2022	WELL #2	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	11/29/2022	WELL #3	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	11/29/2022	WELL #3	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	10/19/2022	WELL #5	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	07/19/2022	WELL #5	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	04/07/2022	WELL #5	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	04/07/2022	WELL #5	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
1,1,1-TRICHLOROETHANE	06/19/2019	WELL #1	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	01/18/2023	WELL #5	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	01/18/2023	WELL #5	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	11/29/2022	WELL #2	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	11/29/2022	WELL #2	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	11/29/2022	WELL #3	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	11/29/2022	WELL #3	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	10/19/2022	WELL #5	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	07/19/2022	WELL #5	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	04/07/2022	WELL #5	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	04/07/2022	WELL #5	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
1,1,2-TRICHLOROETHANE	06/19/2019	WELL #1	Y	0.000		0.000
1,1-DICHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000		0.000
1,1-DICHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000		0.000
1,1-DICHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000		0.000
1,1-DICHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000		0.000
1,1-DICHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000		0.000
1,1-DICHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000		0.000
1,1-DICHLOROETHYLENE	10/19/2022	WELL #5	Y	0.000		0.000
1,1-DICHLOROETHYLENE	07/19/2022	WELL #5	Y	0.000		0.000
1,1-DICHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000		0.000
1,1-DICHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000		0.000
1,1-DICHLOROETHYLENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
1,1-DICHLOROETHYLENE	06/19/2019	WELL #1	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	01/18/2023	WELL #5	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	01/18/2023	WELL #5	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	11/29/2022	WELL #2	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	11/29/2022	WELL #2	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	11/29/2022	WELL #3	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	11/29/2022	WELL #3	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	10/19/2022	WELL #5	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	07/19/2022	WELL #5	Y	0.000		0.000
1,2,4-TRICHLOROBENZENE	04/07/2022	WELL #5	Y	0.000		0.000

Sampling History Report
 Print Date: April 11, 2023

1,2,4-TRICHLOROENZENE	04/07/2022	WELL #5	Y	0.000		0.000
1,2,4-TRICHLOROENZENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
1,2,4-TRICHLOROENZENE	06/19/2019	WELL #1	Y	0.000		0.000
1,2-DIBROMO-3-CHLOROPROPANE	10/19/2022	WELL #5	Y	0.000		0.000
1,2-DIBROMO-3-CHLOROPROPANE	07/19/2022	WELL #5	Y	0.000		0.000
1,2-DIBROMO-3-CHLOROPROPANE	04/07/2022	WELL #5	Y	0.000		0.000
1,2-DIBROMO-3-CHLOROPROPANE	06/19/2019	WELL #1	Y	0.000		0.000
1,2-DIBROMO-3-CHLOROPROPANE	06/17/2019	WELL #2	Y	0.000		0.000
1,2-DIBROMO-3-CHLOROPROPANE	06/17/2019	WELL #3	Y	0.000		0.000
1,2-DIBROMO-3-CHLOROPROPANE	03/20/2019	WELL #1	Y	0.000		0.000
1,2-DICHLOROETHANE	01/18/2023	WELL #5	Y	0.000		0.000
1,2-DICHLOROETHANE	01/18/2023	WELL #5	Y	0.000		0.000
1,2-DICHLOROETHANE	11/29/2022	WELL #2	Y	0.000		0.000
1,2-DICHLOROETHANE	11/29/2022	WELL #2	Y	0.000		0.000
1,2-DICHLOROETHANE	11/29/2022	WELL #3	Y	0.000		0.000
1,2-DICHLOROETHANE	11/29/2022	WELL #3	Y	0.000		0.000
1,2-DICHLOROETHANE	10/19/2022	WELL #5	Y	0.000		0.000
1,2-DICHLOROETHANE	07/19/2022	WELL #5	Y	0.000		0.000
1,2-DICHLOROETHANE	04/07/2022	WELL #5	Y	0.000		0.000
1,2-DICHLOROETHANE	04/07/2022	WELL #5	Y	0.000		0.000
1,2-DICHLOROETHANE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
1,2-DICHLOROETHANE	06/19/2019	WELL #1	Y	0.000		0.000
1,2-DICHLOROPROPANE	01/18/2023	WELL #5	Y	0.000		0.000
1,2-DICHLOROPROPANE	01/18/2023	WELL #5	Y	0.000		0.000
1,2-DICHLOROPROPANE	11/29/2022	WELL #2	Y	0.000		0.000
1,2-DICHLOROPROPANE	11/29/2022	WELL #2	Y	0.000		0.000
1,2-DICHLOROPROPANE	11/29/2022	WELL #3	Y	0.000		0.000
1,2-DICHLOROPROPANE	11/29/2022	WELL #3	Y	0.000		0.000
1,2-DICHLOROPROPANE	10/19/2022	WELL #5	Y	0.000		0.000
1,2-DICHLOROPROPANE	07/19/2022	WELL #5	Y	0.000		0.000
1,2-DICHLOROPROPANE	04/07/2022	WELL #5	Y	0.000		0.000
1,2-DICHLOROPROPANE	04/07/2022	WELL #5	Y	0.000		0.000
1,2-DICHLOROPROPANE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
1,2-DICHLOROPROPANE	06/19/2019	WELL #1	Y	0.000		0.000
2,4,5-TP	01/18/2023	WELL #5	Y	0.000		0.000
2,4,5-TP	10/19/2022	WELL #5	Y	0.000		0.000
2,4,5-TP	07/19/2022	WELL #5	Y	0.000		0.000
2,4,5-TP	04/07/2022	WELL #5	Y	0.000		0.000
2,4,5-TP	06/19/2019	WELL #1	Y	0.000		0.000
2,4,5-TP	06/17/2019	WELL #1	Y	0.000		0.000
2,4,5-TP	06/17/2019	WELL #2	Y	0.000		0.000
2,4,5-TP	06/17/2019	WELL #3	Y	0.000		0.000
2,4,5-TP	03/20/2019	WELL #1	Y	0.000		0.000
2,4-D	01/18/2023	WELL #5	Y	0.000		0.000
2,4-D	10/19/2022	WELL #5	Y	0.000		0.000
2,4-D	07/19/2022	WELL #5	Y	0.000		0.000
2,4-D	04/07/2022	WELL #5	Y	0.000		0.000
2,4-D	06/19/2019	WELL #1	Y	0.000		0.000
2,4-D	06/17/2019	WELL #1	Y	0.000		0.000
2,4-D	06/17/2019	WELL #2	Y	0.000		0.000
2,4-D	06/17/2019	WELL #3	Y	0.000		0.000
2,4-D	03/20/2019	WELL #1	Y	0.000		0.000
ANTIMONY, TOTAL	11/29/2022	WELL #1	Y	0.000		0.000
ANTIMONY, TOTAL	04/07/2022	WELL #5	Y	0.000		0.000
ANTIMONY, TOTAL	06/17/2019	WELL #1	Y	0.000		0.000
ARSENIC	11/30/2022	WELL #1	N	0.001	MG/L	1.000
ARSENIC	11/29/2022	WELL #1	N	0.003	MG/L	3.000
ARSENIC	04/07/2022	WELL #5	N	0.003	MG/L	3.240
ARSENIC	06/17/2019	WELL #1	N	0.003	MG/L	3.000
ATRAZINE	01/18/2023	WELL #5	Y	0.000		0.000
ATRAZINE	10/19/2022	WELL #5	Y	0.000		0.000
ATRAZINE	07/19/2022	WELL #5	Y	0.000		0.000
ATRAZINE	04/07/2022	WELL #5	Y	0.000		0.000
ATRAZINE	06/19/2019	WELL #1	Y	0.000		0.000
ATRAZINE	06/17/2019	WELL #1	Y	0.000		0.000
ATRAZINE	06/17/2019	WELL #2	Y	0.000		0.000
ATRAZINE	06/17/2019	WELL #3	Y	0.000		0.000
ATRAZINE	03/20/2019	WELL #1	Y	0.000		0.000
BARIUM	11/29/2022	WELL #1	N	0.061	MG/L	0.061
BARIUM	04/07/2022	WELL #5	N	0.071	MG/L	0.071
BARIUM	06/17/2019	WELL #1	N	0.064	MG/L	0.064
BENZENE	01/18/2023	WELL #5	Y	0.000		0.000
BENZENE	01/18/2023	WELL #5	Y	0.000		0.000
BENZENE	11/29/2022	WELL #2	Y	0.000		0.000
BENZENE	11/29/2022	WELL #2	Y	0.000		0.000
BENZENE	11/29/2022	WELL #3	Y	0.000		0.000

Sampling History Report
Print Date: April 11, 2023

BENZENE	11/29/2022	WELL #3	Y	0.000		0.000
BENZENE	10/19/2022	WELL #5	Y	0.000		0.000
BENZENE	07/19/2022	WELL #5	Y	0.000		0.000
BENZENE	04/07/2022	WELL #5	Y	0.000		0.000
BENZENE	04/07/2022	WELL #5	Y	0.000		0.000
BENZENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
BENZENE	06/19/2019	WELL #1	Y	0.000		0.000
BENZO(A)PYRENE	01/18/2023	WELL #5	Y	0.000		0.000
BENZO(A)PYRENE	10/19/2022	WELL #5	Y	0.000		0.000
BENZO(A)PYRENE	07/19/2022	WELL #5	Y	0.000		0.000
BENZO(A)PYRENE	04/07/2022	WELL #5	Y	0.000		0.000
BENZO(A)PYRENE	06/19/2019	WELL #1	Y	0.000		0.000
BENZO(A)PYRENE	06/17/2019	WELL #1	Y	0.000		0.000
BENZO(A)PYRENE	06/17/2019	WELL #2	Y	0.000		0.000
BENZO(A)PYRENE	06/17/2019	WELL #3	Y	0.000		0.000
BENZO(A)PYRENE	03/20/2019	WELL #1	Y	0.000		0.000
BERYLLIUM, TOTAL	11/29/2022	WELL #1	Y	0.000		0.000
BERYLLIUM, TOTAL	04/07/2022	WELL #5	Y	0.000		0.000
BERYLLIUM, TOTAL	06/17/2019	WELL #1	Y	0.000		0.000
BHC-GAMMA	01/18/2023	WELL #5	Y	0.000		0.000
BHC-GAMMA	10/19/2022	WELL #5	Y	0.000		0.000
BHC-GAMMA	07/19/2022	WELL #5	Y	0.000		0.000
BHC-GAMMA	04/07/2022	WELL #5	Y	0.000		0.000
BHC-GAMMA	06/19/2019	WELL #1	Y	0.000		0.000
BHC-GAMMA	06/17/2019	WELL #2	Y	0.000		0.000
BHC-GAMMA	06/17/2019	WELL #3	Y	0.000		0.000
BHC-GAMMA	03/20/2019	WELL #1	Y	0.000		0.000
CADMIUM	11/29/2022	WELL #1	Y	0.000		0.000
CADMIUM	04/07/2022	WELL #5	Y	0.000		0.000
CADMIUM	06/17/2019	WELL #1	Y	0.000		0.000
CARBOFURAN	01/18/2023	WELL #5	Y	0.000		0.000
CARBOFURAN	10/19/2022	WELL #5	Y	0.000		0.000
CARBOFURAN	07/19/2022	WELL #5	Y	0.000		0.000
CARBOFURAN	04/07/2022	WELL #5	Y	0.000		0.000
CARBOFURAN	06/19/2019	WELL #1	Y	0.000		0.000
CARBOFURAN	06/17/2019	WELL #2	Y	0.000		0.000
CARBOFURAN	06/17/2019	WELL #3	Y	0.000		0.000
CARBOFURAN	03/20/2019	WELL #1	Y	0.000		0.000
CARBON TETRACHLORIDE	01/18/2023	WELL #5	Y	0.000		0.000
CARBON TETRACHLORIDE	01/18/2023	WELL #5	Y	0.000		0.000
CARBON TETRACHLORIDE	11/29/2022	WELL #2	Y	0.000		0.000
CARBON TETRACHLORIDE	11/29/2022	WELL #2	Y	0.000		0.000
CARBON TETRACHLORIDE	11/29/2022	WELL #3	Y	0.000		0.000
CARBON TETRACHLORIDE	11/29/2022	WELL #3	Y	0.000		0.000
CARBON TETRACHLORIDE	10/19/2022	WELL #5	Y	0.000		0.000
CARBON TETRACHLORIDE	07/19/2022	WELL #5	Y	0.000		0.000
CARBON TETRACHLORIDE	04/07/2022	WELL #5	Y	0.000		0.000
CARBON TETRACHLORIDE	04/07/2022	WELL #5	Y	0.000		0.000
CARBON TETRACHLORIDE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
CARBON TETRACHLORIDE	06/19/2019	WELL #1	Y	0.000		0.000
CHLORDANE	10/19/2022	WELL #5	Y	0.000		0.000
CHLORDANE	07/19/2022	WELL #5	Y	0.000		0.000
CHLORDANE	04/07/2022	WELL #5	Y	0.000		0.000
CHLORDANE	06/19/2019	WELL #1	Y	0.000		0.000
CHLORDANE	06/17/2019	WELL #2	Y	0.000		0.000
CHLORDANE	06/17/2019	WELL #3	Y	0.000		0.000
CHLORDANE	03/20/2019	WELL #1	Y	0.000		0.000
CHLORO BENZENE	01/18/2023	WELL #5	Y	0.000		0.000
CHLORO BENZENE	01/18/2023	WELL #5	Y	0.000		0.000
CHLORO BENZENE	11/29/2022	WELL #2	Y	0.000		0.000
CHLORO BENZENE	11/29/2022	WELL #2	Y	0.000		0.000
CHLORO BENZENE	11/29/2022	WELL #3	Y	0.000		0.000
CHLORO BENZENE	11/29/2022	WELL #3	Y	0.000		0.000
CHLORO BENZENE	10/19/2022	WELL #5	Y	0.000		0.000
CHLORO BENZENE	07/19/2022	WELL #5	Y	0.000		0.000
CHLORO BENZENE	04/07/2022	WELL #5	Y	0.000		0.000
CHLORO BENZENE	04/07/2022	WELL #5	Y	0.000		0.000
CHLORO BENZENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
CHLORO BENZENE	06/19/2019	WELL #1	Y	0.000		0.000
CHROMIUM	11/29/2022	WELL #1	Y	0.000		0.000
CHROMIUM	04/07/2022	WELL #5	N	0.002	MG/L	1.780
CHROMIUM	06/17/2019	WELL #1	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000		0.000

Sampling History Report
Print Date: April 11, 2023

CIS-1,2-DICHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	10/19/2022	WELL #5	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	07/19/2022	WELL #5	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
CIS-1,2-DICHLOROETHYLENE	06/19/2019	WELL #1	Y	0.000		0.000
COMBINED RADIUM (-226 & -228)	10/19/2022	WELL #5		0.083	PCI/L	0.083
COMBINED RADIUM (-226 & -228)	07/19/2022	WELL #5	Y	0.000		0.000
COMBINED RADIUM (-226 & -228)	04/07/2022	WELL #5		0.528	PCI/L	0.528
COMBINED URANIUM	10/19/2022	WELL #5	Y	0.000		0.000
COMBINED URANIUM	07/19/2022	WELL #5	Y	0.000		0.000
COMBINED URANIUM	04/07/2022	WELL #5	Y	0.000		0.000
COMBINED URANIUM	06/17/2019	WELL #3	N	0.820	UG/L	0.820
COMBINED URANIUM	03/27/2019	HAILEY CREEK WELL # 4	N	0.720	UG/L	0.720
CYANIDE	04/07/2022	WELL #5	Y	0.000		0.000
DALAPON	01/18/2023	WELL #5	Y	0.000		0.000
DALAPON	10/19/2022	WELL #5	Y	0.000		0.000
DALAPON	07/19/2022	WELL #5	Y	0.000		0.000
DALAPON	04/07/2022	WELL #5	Y	0.000		0.000
DALAPON	06/19/2019	WELL #1	Y	0.000		0.000
DALAPON	06/17/2019	WELL #1	Y	0.000		0.000
DALAPON	06/17/2019	WELL #2	Y	0.000		0.000
DALAPON	06/17/2019	WELL #3	Y	0.000		0.000
DALAPON	03/20/2019	WELL #1	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	01/18/2023	WELL #5	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	10/19/2022	WELL #5	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	07/19/2022	WELL #5	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	04/07/2022	WELL #5	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	06/19/2019	WELL #1	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	06/17/2019	WELL #1	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	06/17/2019	WELL #2	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	06/17/2019	WELL #3	Y	0.000		0.000
DI(2-ETHYLHEXYL) ADIPATE	03/20/2019	WELL #1	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	01/18/2023	WELL #5	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	10/19/2022	WELL #5	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	07/19/2022	WELL #5	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	04/07/2022	WELL #5	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	06/19/2019	WELL #1	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	06/17/2019	WELL #1	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	06/17/2019	WELL #2	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	06/17/2019	WELL #3	Y	0.000		0.000
DI(2-ETHYLHEXYL) PHTHALATE	03/20/2019	WELL #1	Y	0.000		0.000
DICHLOROMETHANE	01/18/2023	WELL #5	Y	0.000		0.000
DICHLOROMETHANE	01/18/2023	WELL #5	Y	0.000		0.000
DICHLOROMETHANE	11/29/2022	WELL #2	Y	0.000		0.000
DICHLOROMETHANE	11/29/2022	WELL #2	Y	0.000		0.000
DICHLOROMETHANE	11/29/2022	WELL #3	Y	0.000		0.000
DICHLOROMETHANE	11/29/2022	WELL #3	Y	0.000		0.000
DICHLOROMETHANE	10/19/2022	WELL #5	Y	0.000		0.000
DICHLOROMETHANE	07/19/2022	WELL #5	Y	0.000		0.000
DICHLOROMETHANE	04/07/2022	WELL #5	Y	0.000		0.000
DICHLOROMETHANE	04/07/2022	WELL #5	Y	0.000		0.000
DICHLOROMETHANE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
DICHLOROMETHANE	06/19/2019	WELL #1	Y	0.000		0.000
DINOSEB	01/18/2023	WELL #5	Y	0.000		0.000
DINOSEB	10/19/2022	WELL #5	Y	0.000		0.000
DINOSEB	07/19/2022	WELL #5	Y	0.000		0.000
DINOSEB	04/07/2022	WELL #5	Y	0.000		0.000
DINOSEB	06/19/2019	WELL #1	Y	0.000		0.000
DINOSEB	06/17/2019	WELL #1	Y	0.000		0.000
DINOSEB	06/17/2019	WELL #2	Y	0.000		0.000
DINOSEB	06/17/2019	WELL #3	Y	0.000		0.000
DINOSEB	03/20/2019	WELL #1	Y	0.000		0.000
DIQUAT	01/18/2023	WELL #5	Y	0.000		0.000
DIQUAT	10/19/2022	WELL #5	Y	0.000		0.000
DIQUAT	07/19/2022	WELL #5	Y	0.000		0.000
DIQUAT	04/07/2022	WELL #5	Y	0.000		0.000
DIQUAT	06/19/2019	WELL #1	Y	0.000		0.000
DIQUAT	06/17/2019	WELL #1	Y	0.000		0.000
DIQUAT	06/17/2019	WELL #2	Y	0.000		0.000
DIQUAT	06/17/2019	WELL #3	Y	0.000		0.000
DIQUAT	03/20/2019	WELL #1	Y	0.000		0.000
ENDOTHALL	01/18/2023	WELL #5	Y	0.000		0.000
ENDOTHALL	10/19/2022	WELL #5	Y	0.000		0.000

Sampling History Report
Print Date: April 11, 2023

ENDOTHALL	07/19/2022	WELL #5	Y	0.000		0.000
ENDOTHALL	04/07/2022	WELL #5	Y	0.000		0.000
ENDOTHALL	06/19/2019	WELL #1	Y	0.000		0.000
ENDOTHALL	06/17/2019	WELL #1	Y	0.000		0.000
ENDOTHALL	06/17/2019	WELL #2	Y	0.000		0.000
ENDOTHALL	06/17/2019	WELL #3	Y	0.000		0.000
ENDOTHALL	03/20/2019	WELL #1	Y	0.000		0.000
ENDRIN	01/18/2023	WELL #5	Y	0.000		0.000
ENDRIN	10/19/2022	WELL #5	Y	0.000		0.000
ENDRIN	07/19/2022	WELL #5	Y	0.000		0.000
ENDRIN	04/07/2022	WELL #5	Y	0.000		0.000
ENDRIN	06/19/2019	WELL #1	Y	0.000		0.000
ENDRIN	06/17/2019	WELL #2	Y	0.000		0.000
ENDRIN	06/17/2019	WELL #3	Y	0.000		0.000
ENDRIN	03/20/2019	WELL #1	Y	0.000		0.000
ETHYLBENZENE	01/18/2023	WELL #5	Y	0.000		0.000
ETHYLBENZENE	01/18/2023	WELL #5	Y	0.000		0.000
ETHYLBENZENE	11/29/2022	WELL #2	Y	0.000		0.000
ETHYLBENZENE	11/29/2022	WELL #2	Y	0.000		0.000
ETHYLBENZENE	11/29/2022	WELL #3	Y	0.000		0.000
ETHYLBENZENE	11/29/2022	WELL #3	Y	0.000		0.000
ETHYLBENZENE	10/19/2022	WELL #5	Y	0.000		0.000
ETHYLBENZENE	07/19/2022	WELL #5	Y	0.000		0.000
ETHYLBENZENE	04/07/2022	WELL #5	Y	0.000		0.000
ETHYLBENZENE	04/07/2022	WELL #5	Y	0.000		0.000
ETHYLBENZENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
ETHYLBENZENE	06/19/2019	WELL #1	Y	0.000		0.000
ETHYLENE DIBROMIDE	10/19/2022	WELL #5	Y	0.000		0.000
ETHYLENE DIBROMIDE	07/19/2022	WELL #5	Y	0.000		0.000
ETHYLENE DIBROMIDE	04/07/2022	WELL #5	Y	0.000		0.000
ETHYLENE DIBROMIDE	06/19/2019	WELL #1	Y	0.000		0.000
ETHYLENE DIBROMIDE	06/17/2019	WELL #2	Y	0.000		0.000
ETHYLENE DIBROMIDE	06/17/2019	WELL #3	Y	0.000		0.000
ETHYLENE DIBROMIDE	03/20/2019	WELL #1	Y	0.000		0.000
FLUORIDE	11/29/2022	WELL #1	N	0.298	MG/L	0.298
FLUORIDE	04/07/2022	WELL #5	N	0.349	MG/L	0.349
FLUORIDE	06/17/2019	WELL #1	N	0.400	MG/L	0.400
GLYPHOSATE	01/18/2023	WELL #5	Y	0.000		0.000
GLYPHOSATE	10/19/2022	WELL #5	Y	0.000		0.000
GLYPHOSATE	07/19/2022	WELL #5	Y	0.000		0.000
GLYPHOSATE	04/07/2022	WELL #5	Y	0.000		0.000
GLYPHOSATE	06/19/2019	WELL #1	Y	0.000		0.000
GLYPHOSATE	06/17/2019	WELL #2	Y	0.000		0.000
GLYPHOSATE	06/17/2019	WELL #3	Y	0.000		0.000
GLYPHOSATE	03/20/2019	WELL #1	Y	0.000		0.000
GROSS ALPHA, EXCL. RADON & U	10/19/2022	WELL #5	Y	0.000		0.000
GROSS ALPHA, EXCL. RADON & U	07/19/2022	WELL #5	Y	0.000		0.000
GROSS ALPHA, EXCL. RADON & U	04/07/2022	WELL #5	Y	0.000		0.000
GROSS ALPHA, EXCL. RADON & U	06/17/2019	WELL #3		0.940	PCI/L	0.940
GROSS ALPHA, INCL. RADON & U	10/19/2022	WELL #5	Y	0.000		0.000
GROSS ALPHA, INCL. RADON & U	07/19/2022	WELL #5	Y	0.000		0.000
GROSS ALPHA, INCL. RADON & U	04/07/2022	WELL #5	Y	0.000		0.000
GROSS ALPHA, INCL. RADON & U	06/17/2019	WELL #3	N	1.490	PCI/L	1.490
GROSS BETA PARTICLE ACTIVITY	04/07/2022	WELL #5	Y	0.000		0.000
HEPTACHLOR	01/18/2023	WELL #5	Y	0.000		0.000
HEPTACHLOR	10/19/2022	WELL #5	Y	0.000		0.000
HEPTACHLOR	07/19/2022	WELL #5	Y	0.000		0.000
HEPTACHLOR	04/07/2022	WELL #5	Y	0.000		0.000
HEPTACHLOR	06/19/2019	WELL #1	Y	0.000		0.000
HEPTACHLOR	06/17/2019	WELL #2	Y	0.000		0.000
HEPTACHLOR	06/17/2019	WELL #3	Y	0.000		0.000
HEPTACHLOR	03/20/2019	WELL #1	Y	0.000		0.000
HEPTACHLOR EPOXIDE	01/18/2023	WELL #5	Y	0.000		0.000
HEPTACHLOR EPOXIDE	10/19/2022	WELL #5	Y	0.000		0.000
HEPTACHLOR EPOXIDE	07/19/2022	WELL #5	Y	0.000		0.000
HEPTACHLOR EPOXIDE	04/07/2022	WELL #5	Y	0.000		0.000
HEPTACHLOR EPOXIDE	06/19/2019	WELL #1	Y	0.000		0.000
HEPTACHLOR EPOXIDE	06/17/2019	WELL #2	Y	0.000		0.000
HEPTACHLOR EPOXIDE	06/17/2019	WELL #3	Y	0.000		0.000
HEPTACHLOR EPOXIDE	03/20/2019	WELL #1	Y	0.000		0.000
HEXACHLOROBENZENE	01/18/2023	WELL #5	Y	0.000		0.000
HEXACHLOROBENZENE	10/19/2022	WELL #5	Y	0.000		0.000
HEXACHLOROBENZENE	07/19/2022	WELL #5	Y	0.000		0.000
HEXACHLOROBENZENE	04/07/2022	WELL #5	Y	0.000		0.000
HEXACHLOROBENZENE	06/19/2019	WELL #1	Y	0.000		0.000
HEXACHLOROBENZENE	06/17/2019	WELL #1	Y	0.000		0.000

Sampling History Report
 Print Date: April 11, 2023

HEXACHLOROBENZENE	06/17/2019	WELL #2	Y	0.000		0.000
HEXACHLOROBENZENE	06/17/2019	WELL #3	Y	0.000		0.000
HEXACHLOROBENZENE	03/20/2019	WELL #1	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	01/18/2023	WELL #5	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	10/19/2022	WELL #5	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	07/19/2022	WELL #5	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	04/07/2022	WELL #5	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	06/19/2019	WELL #1	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	06/17/2019	WELL #1	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	06/17/2019	WELL #2	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	06/17/2019	WELL #3	Y	0.000		0.000
HEXACHLOROCYCLOPENTADIENE	03/20/2019	WELL #1	Y	0.000		0.000
LASSO	01/18/2023	WELL #5	Y	0.000		0.000
LASSO	10/19/2022	WELL #5	Y	0.000		0.000
LASSO	07/19/2022	WELL #5	Y	0.000		0.000
LASSO	04/07/2022	WELL #5	Y	0.000		0.000
LASSO	06/19/2019	WELL #1	Y	0.000		0.000
LASSO	06/17/2019	WELL #1	Y	0.000		0.000
LASSO	06/17/2019	WELL #2	Y	0.000		0.000
LASSO	06/17/2019	WELL #3	Y	0.000		0.000
LASSO	03/20/2019	WELL #1	Y	0.000		0.000
MERCURY	11/29/2022	WELL #1	Y	0.000		0.000
MERCURY	04/07/2022	WELL #5	Y	0.000		0.000
MERCURY	06/17/2019	WELL #1	Y	0.000		0.000
METHOXYCHLOR	01/18/2023	WELL #5	Y	0.000		0.000
METHOXYCHLOR	10/19/2022	WELL #5	Y	0.000		0.000
METHOXYCHLOR	07/19/2022	WELL #5	Y	0.000		0.000
METHOXYCHLOR	04/07/2022	WELL #5	Y	0.000		0.000
METHOXYCHLOR	06/19/2019	WELL #1	Y	0.000		0.000
METHOXYCHLOR	06/17/2019	WELL #2	Y	0.000		0.000
METHOXYCHLOR	06/17/2019	WELL #3	Y	0.000		0.000
METHOXYCHLOR	03/20/2019	WELL #1	Y	0.000		0.000
NICKEL	11/29/2022	WELL #1	Y	0.000		0.000
NICKEL	04/07/2022	WELL #5	Y	0.000		0.000
NICKEL	06/17/2019	WELL #1	Y	0.000		0.000
NITRATE	11/21/2022	HAILEY CREEK WELL # 4	Y	0.000		0.000
NITRATE	11/21/2022	WELL #1	Y	0.000		0.000
NITRATE	11/21/2022	WELL #2	Y	0.000		0.000
NITRATE	11/21/2022	WELL #3	Y	0.000		0.000
NITRATE	11/21/2022	WELL #5	N	2.410	MG/L	2.410
NITRATE	07/26/2021	HAILEY CREEK WELL # 4	Y	0.000		0.000
NITRATE	07/26/2021	WELL #1	Y	0.000		0.000
NITRATE	07/26/2021	WELL #2	Y	0.000		0.000
NITRATE	07/26/2021	WELL #3	Y	0.000		0.000
NITRATE	02/12/2020	HAILEY CREEK WELL # 4	Y	0.000		0.000
NITRATE	02/12/2020	WELL #1	Y	0.000		0.000
NITRATE	02/12/2020	WELL #2	Y	0.000		0.000
NITRATE	02/12/2020	WELL #3	Y	0.000		0.000
NITRATE	06/17/2019	WELL #1	N	1.180	MG/L	1.180
NITRATE	06/17/2019	WELL #2	N	1.590	MG/L	1.590
NITRATE	06/17/2019	WELL #3	N	1.070	MG/L	1.070
NITRATE	03/27/2019	HAILEY CREEK WELL # 4	N	1.090	MG/L	1.090
NITRATE	10/31/2018	HAILEY CREEK WELL # 4	N	1.070	MG/L	1.070
NITRATE	10/31/2018	WELL #1	N	1.080	MG/L	1.080
NITRATE	10/31/2018	WELL #2	N	1.080	MG/L	1.080
NITRATE	10/31/2018	WELL #3	Y	0.000		0.000
NITRITE	06/17/2019	WELL #1	Y	0.000		0.000
O-DICHLOROBENZENE	01/18/2023	WELL #5	Y	0.000		0.000
O-DICHLOROBENZENE	01/18/2023	WELL #5	Y	0.000		0.000
O-DICHLOROBENZENE	11/29/2022	WELL #2	Y	0.000		0.000
O-DICHLOROBENZENE	11/29/2022	WELL #2	Y	0.000		0.000
O-DICHLOROBENZENE	11/29/2022	WELL #3	Y	0.000		0.000
O-DICHLOROBENZENE	11/29/2022	WELL #3	Y	0.000		0.000
O-DICHLOROBENZENE	10/19/2022	WELL #5	Y	0.000		0.000
O-DICHLOROBENZENE	07/19/2022	WELL #5	Y	0.000		0.000
O-DICHLOROBENZENE	04/07/2022	WELL #5	Y	0.000		0.000
O-DICHLOROBENZENE	04/07/2022	WELL #5	Y	0.000		0.000
O-DICHLOROBENZENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
O-DICHLOROBENZENE	06/19/2019	WELL #1	Y	0.000		0.000
OXAMYL	01/18/2023	WELL #5	Y	0.000		0.000
OXAMYL	10/19/2022	WELL #5	Y	0.000		0.000
OXAMYL	07/19/2022	WELL #5	Y	0.000		0.000
OXAMYL	04/07/2022	WELL #5	Y	0.000		0.000
OXAMYL	06/19/2019	WELL #1	Y	0.000		0.000
OXAMYL	06/17/2019	WELL #2	Y	0.000		0.000
OXAMYL	06/17/2019	WELL #3	Y	0.000		0.000

Sampling History Report
Print Date: April 11, 2023

OXAMYL	03/20/2019	WELL #1	Y	0.000		0.000
P-DICHLOROENZENE	01/18/2023	WELL #5	Y	0.000		0.000
P-DICHLOROENZENE	01/18/2023	WELL #5	Y	0.000		0.000
P-DICHLOROENZENE	11/29/2022	WELL #2	Y	0.000		0.000
P-DICHLOROENZENE	11/29/2022	WELL #2	Y	0.000		0.000
P-DICHLOROENZENE	11/29/2022	WELL #3	Y	0.000		0.000
P-DICHLOROENZENE	11/29/2022	WELL #3	Y	0.000		0.000
P-DICHLOROENZENE	10/19/2022	WELL #5	Y	0.000		0.000
P-DICHLOROENZENE	07/19/2022	WELL #5	Y	0.000		0.000
P-DICHLOROENZENE	04/07/2022	WELL #5	Y	0.000		0.000
P-DICHLOROENZENE	04/07/2022	WELL #5	Y	0.000		0.000
P-DICHLOROENZENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
P-DICHLOROENZENE	06/19/2019	WELL #1	Y	0.000		0.000
PENTACHLOROPHENOL	01/18/2023	WELL #5	Y	0.000		0.000
PENTACHLOROPHENOL	10/19/2022	WELL #5	Y	0.000		0.000
PENTACHLOROPHENOL	07/19/2022	WELL #5	Y	0.000		0.000
PENTACHLOROPHENOL	04/07/2022	WELL #5	Y	0.000		0.000
PENTACHLOROPHENOL	06/19/2019	WELL #1	Y	0.000		0.000
PENTACHLOROPHENOL	06/17/2019	WELL #1	Y	0.000		0.000
PENTACHLOROPHENOL	06/17/2019	WELL #2	Y	0.000		0.000
PENTACHLOROPHENOL	06/17/2019	WELL #3	Y	0.000		0.000
PENTACHLOROPHENOL	03/20/2019	WELL #1	Y	0.000		0.000
PICLORAM	01/18/2023	WELL #5	Y	0.000		0.000
PICLORAM	10/19/2022	WELL #5	Y	0.000		0.000
PICLORAM	07/19/2022	WELL #5	Y	0.000		0.000
PICLORAM	04/07/2022	WELL #5	Y	0.000		0.000
PICLORAM	06/19/2019	WELL #1	Y	0.000		0.000
PICLORAM	06/17/2019	WELL #1	Y	0.000		0.000
PICLORAM	06/17/2019	WELL #2	Y	0.000		0.000
PICLORAM	06/17/2019	WELL #3	Y	0.000		0.000
PICLORAM	03/20/2019	WELL #1	Y	0.000		0.000
RADIUM-226	10/19/2022	WELL #5	N	0.083	PCI/L	0.083
RADIUM-226	07/19/2022	WELL #5	Y	0.000		0.000
RADIUM-226	04/07/2022	WELL #5	Y	0.000		0.000
RADIUM-228	10/19/2022	WELL #5	Y	0.000		0.000
RADIUM-228	07/19/2022	WELL #5	Y	0.000		0.000
RADIUM-228	04/07/2022	WELL #5	N	0.528	PCI/L	0.528
SELENIUM	11/29/2022	WELL #1	Y	0.000		0.000
SELENIUM	04/07/2022	WELL #5	Y	0.000		0.000
SELENIUM	06/17/2019	WELL #1	N	0.005	MG/L	5.000
SIMAZINE	01/18/2023	WELL #5	Y	0.000		0.000
SIMAZINE	10/19/2022	WELL #5	Y	0.000		0.000
SIMAZINE	07/19/2022	WELL #5	Y	0.000		0.000
SIMAZINE	04/07/2022	WELL #5	Y	0.000		0.000
SIMAZINE	06/19/2019	WELL #1	Y	0.000		0.000
SIMAZINE	06/17/2019	WELL #1	Y	0.000		0.000
SIMAZINE	06/17/2019	WELL #2	Y	0.000		0.000
SIMAZINE	06/17/2019	WELL #3	Y	0.000		0.000
SIMAZINE	03/20/2019	WELL #1	Y	0.000		0.000
STYRENE	01/18/2023	WELL #5	Y	0.000		0.000
STYRENE	01/18/2023	WELL #5	Y	0.000		0.000
STYRENE	11/29/2022	WELL #2	Y	0.000		0.000
STYRENE	11/29/2022	WELL #2	Y	0.000		0.000
STYRENE	11/29/2022	WELL #3	Y	0.000		0.000
STYRENE	11/29/2022	WELL #3	Y	0.000		0.000
STYRENE	10/19/2022	WELL #5	Y	0.000		0.000
STYRENE	07/19/2022	WELL #5	Y	0.000		0.000
STYRENE	04/07/2022	WELL #5	Y	0.000		0.000
STYRENE	04/07/2022	WELL #5	Y	0.000		0.000
STYRENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
STYRENE	06/19/2019	WELL #1	Y	0.000		0.000
TETRACHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000		0.000
TETRACHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000		0.000
TETRACHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000		0.000
TETRACHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000		0.000
TETRACHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000		0.000
TETRACHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000		0.000
TETRACHLOROETHYLENE	10/19/2022	WELL #5	Y	0.000		0.000
TETRACHLOROETHYLENE	07/19/2022	WELL #5	Y	0.000		0.000
TETRACHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000		0.000
TETRACHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000		0.000
TETRACHLOROETHYLENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000		0.000
TETRACHLOROETHYLENE	06/19/2019	WELL #1	Y	0.000		0.000
THALLIUM, TOTAL	11/29/2022	WELL #1	Y	0.000		0.000
THALLIUM, TOTAL	04/07/2022	WELL #5	Y	0.000		0.000
THALLIUM, TOTAL	06/17/2019	WELL #1	Y	0.000		0.000

Sampling History Report
Print Date: April 11, 2023

TOLUENE	01/18/2023	WELL #5	Y	0.000	0.000
TOLUENE	01/18/2023	WELL #5	Y	0.000	0.000
TOLUENE	11/29/2022	WELL #2	Y	0.000	0.000
TOLUENE	11/29/2022	WELL #2	Y	0.000	0.000
TOLUENE	11/29/2022	WELL #3	Y	0.000	0.000
TOLUENE	11/29/2022	WELL #3	Y	0.000	0.000
TOLUENE	10/19/2022	WELL #5	Y	0.000	0.000
TOLUENE	07/19/2022	WELL #5	Y	0.000	0.000
TOLUENE	04/07/2022	WELL #5	Y	0.000	0.000
TOLUENE	04/07/2022	WELL #5	Y	0.000	0.000
TOLUENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000	0.000
TOLUENE	06/19/2019	WELL #1	Y	0.000	0.000
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	10/19/2022	WELL #5	Y	0.000	0.000
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	07/19/2022	WELL #5	Y	0.000	0.000
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	04/07/2022	WELL #5	Y	0.000	0.000
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	06/19/2019	WELL #1	Y	0.000	0.000
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	06/17/2019	WELL #2	Y	0.000	0.000
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	06/17/2019	WELL #3	Y	0.000	0.000
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	03/20/2019	WELL #1	Y	0.000	0.000
TOXAPHENE	01/18/2023	WELL #5	Y	0.000	0.000
TOXAPHENE	10/19/2022	WELL #5	Y	0.000	0.000
TOXAPHENE	07/19/2022	WELL #5	Y	0.000	0.000
TOXAPHENE	04/07/2022	WELL #5	Y	0.000	0.000
TOXAPHENE	06/19/2019	WELL #1	Y	0.000	0.000
TOXAPHENE	06/17/2019	WELL #2	Y	0.000	0.000
TOXAPHENE	06/17/2019	WELL #3	Y	0.000	0.000
TOXAPHENE	03/20/2019	WELL #1	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	10/19/2022	WELL #5	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	07/19/2022	WELL #5	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000	0.000
TRANS-1,2-DICHLOROETHYLENE	06/19/2019	WELL #1	Y	0.000	0.000
TRICHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000	0.000
TRICHLOROETHYLENE	01/18/2023	WELL #5	Y	0.000	0.000
TRICHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000	0.000
TRICHLOROETHYLENE	11/29/2022	WELL #2	Y	0.000	0.000
TRICHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000	0.000
TRICHLOROETHYLENE	11/29/2022	WELL #3	Y	0.000	0.000
TRICHLOROETHYLENE	10/19/2022	WELL #5	Y	0.000	0.000
TRICHLOROETHYLENE	07/19/2022	WELL #5	Y	0.000	0.000
TRICHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000	0.000
TRICHLOROETHYLENE	04/07/2022	WELL #5	Y	0.000	0.000
TRICHLOROETHYLENE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000	0.000
TRICHLOROETHYLENE	06/19/2019	WELL #1	Y	0.000	0.000
VINYL CHLORIDE	01/18/2023	WELL #5	Y	0.000	0.000
VINYL CHLORIDE	01/18/2023	WELL #5	Y	0.000	0.000
VINYL CHLORIDE	11/29/2022	WELL #2	Y	0.000	0.000
VINYL CHLORIDE	11/29/2022	WELL #2	Y	0.000	0.000
VINYL CHLORIDE	11/29/2022	WELL #3	Y	0.000	0.000
VINYL CHLORIDE	11/29/2022	WELL #3	Y	0.000	0.000
VINYL CHLORIDE	10/19/2022	WELL #5	Y	0.000	0.000
VINYL CHLORIDE	07/19/2022	WELL #5	Y	0.000	0.000
VINYL CHLORIDE	04/07/2022	WELL #5	Y	0.000	0.000
VINYL CHLORIDE	04/07/2022	WELL #5	Y	0.000	0.000
VINYL CHLORIDE	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000	0.000
VINYL CHLORIDE	06/19/2019	WELL #1	Y	0.000	0.000
XYLENES, TOTAL	01/18/2023	WELL #5	Y	0.000	0.000
XYLENES, TOTAL	01/18/2023	WELL #5	Y	0.000	0.000
XYLENES, TOTAL	11/29/2022	WELL #2	Y	0.000	0.000
XYLENES, TOTAL	11/29/2022	WELL #2	Y	0.000	0.000
XYLENES, TOTAL	11/29/2022	WELL #3	Y	0.000	0.000
XYLENES, TOTAL	11/29/2022	WELL #3	Y	0.000	0.000
XYLENES, TOTAL	10/19/2022	WELL #5	Y	0.000	0.000
XYLENES, TOTAL	07/19/2022	WELL #5	Y	0.000	0.000
XYLENES, TOTAL	04/07/2022	WELL #5	Y	0.000	0.000
XYLENES, TOTAL	04/07/2022	WELL #5	Y	0.000	0.000
XYLENES, TOTAL	06/19/2019	HAILEY CREEK WELL # 4	Y	0.000	0.000
XYLENES, TOTAL	06/19/2019	WELL #1	Y	0.000	0.000

Sampling History Report
Print Date: April 11, 2023

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.

Coliform Sampling History
 PWS Number: ID7260032
 PWS Name: RIGBY CITY OF
 Total Records: 48

Only report coliform results in the CCR if one or more samples tested positive during the 2022 calendar year.

Required Language. If your water system's coliform history for the year included one or more samples present for coliform, you must give the major sources of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Major Sources in Drinking Water" column and place it in your CCR. If the system has exceeded the MCL (maximum contaminant level) value for coliforms, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Health Effects Language" column and place it in your CCR.

Coliform Sampling History
 Total Records: 48

Contaminant	Date Collected	P=Present A=Absent
COLIFORM (TCR)	12/05/2022	A
COLIFORM (TCR)	12/05/2022	A
COLIFORM (TCR)	12/05/2022	A
COLIFORM (TCR)	12/05/2022	A
COLIFORM (TCR)	11/07/2022	A
COLIFORM (TCR)	11/07/2022	A
COLIFORM (TCR)	11/07/2022	A
COLIFORM (TCR)	11/07/2022	A
COLIFORM (TCR)	10/05/2022	A
COLIFORM (TCR)	10/05/2022	A
COLIFORM (TCR)	10/05/2022	A
COLIFORM (TCR)	10/05/2022	A
COLIFORM (TCR)	09/12/2022	A
COLIFORM (TCR)	09/12/2022	A
COLIFORM (TCR)	09/12/2022	A
COLIFORM (TCR)	09/12/2022	A
COLIFORM (TCR)	08/02/2022	A
COLIFORM (TCR)	08/02/2022	A
COLIFORM (TCR)	08/02/2022	A
COLIFORM (TCR)	08/02/2022	A
COLIFORM (TCR)	07/05/2022	A
COLIFORM (TCR)	07/05/2022	A
COLIFORM (TCR)	07/05/2022	A
COLIFORM (TCR)	06/06/2022	A
COLIFORM (TCR)	06/06/2022	A
COLIFORM (TCR)	06/06/2022	A
COLIFORM (TCR)	06/06/2022	A
COLIFORM (TCR)	05/09/2022	A
COLIFORM (TCR)	05/09/2022	A
COLIFORM (TCR)	05/09/2022	A
COLIFORM (TCR)	05/09/2022	A
COLIFORM (TCR)	04/04/2022	A
COLIFORM (TCR)	04/04/2022	A
COLIFORM (TCR)	04/04/2022	A
COLIFORM (TCR)	04/04/2022	A
COLIFORM (TCR)	03/02/2022	A
COLIFORM (TCR)	03/02/2022	A
COLIFORM (TCR)	03/02/2022	A
COLIFORM (TCR)	03/02/2022	A
COLIFORM (TCR)	02/07/2022	A
COLIFORM (TCR)	02/07/2022	A
COLIFORM (TCR)	02/07/2022	A
COLIFORM (TCR)	02/07/2022	A
COLIFORM (TCR)	01/10/2022	A
COLIFORM (TCR)	01/10/2022	A
COLIFORM (TCR)	01/10/2022	A
COLIFORM (TCR)	01/10/2022	A

Sampling History Report
Print Date: April 11, 2023

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.

Lead And Copper Sampling History
PWS Number: ID7260032
PWS Name: RIGBY CITY OF
Total Records: 6

A public water system is only required to report the most recent 90% percentile detections for lead and copper within the past five years. If a result is listed as zero, it should be assumed the result was actually a non-detect.

Other lead and copper information to be included in the CCR not listed on this page are the number of samples collected from the distribution system, and the highest level of lead or copper that was detected.

Required Language. If there are detections for lead and copper to report, the system must give the major sources of the contaminant. If a system reports a detection, the system must give the major sources of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Major Sources in Drinking Water" column and place it in your CCR. If the system exceeds the MCL (maximum contaminant level) value of a contaminant, the system must show the potential health effects of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Health Effects Language" column and place it in your CCR.

Abbreviations used below:

MG/L (mg/L) = milligrams per liter (mg/L = ppm in Appendix A)

UG/L (µg/L) = micrograms per liter (µg/L = ppb in Appendix A)

Contaminant	# Samples Collected	90th %ile Result	Units	Date Collected	CCR Units
LEAD SUMMARY	40	0.002	MG/L	04/26/2022	2.000
COPPER SUMMARY	40	0.064	MG/L	04/26/2022	0.064
LEAD SUMMARY	20	0.002	MG/L	09/08/2021	2.000
COPPER SUMMARY	20	0.064	MG/L	09/08/2021	0.064
LEAD SUMMARY	20	0.001	MG/L	07/26/2018	1.000
COPPER SUMMARY	20	0.118	MG/L	07/26/2018	0.118

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.

DBP Sampling History
PWS Number: ID7260032
PWS Name: RIGBY CITY OF
Total Records: 1

Sampling history is only listed for systems which are practicing chlorination on a full-time basis.

Public water systems that are required to collect one sample for disinfection byproducts once every year, or every three years, are only required to report the most recent detections for disinfection byproducts. If the most recent sampling was a non-detect for the contaminants, then it is not necessary to report any disinfection byproduct sampling. **Note:** If a contaminant is listed with a "Y" (meaning "Yes") in the "non-detect" column, this means that sampling results showed a "non-detect" - that is to say, the contaminant was not detected.

If a public water system collects more than one sample per year, the system must report the average of Total Trihalomethanes and Haloacetic Acids Group 5 over the 2022 calendar year. The highest level detected, and the range for each contaminant must also be reported.

Required Language. If a system reports a detection, the system must give the major sources of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Major Sources in Drinking Water" column and place it in your CCR. If the system has exceeded the MCL (maximum contaminant level) value of a contaminant, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the "Health Effects Language" column and place it in your CCR.

Contaminant	Date Collected	Sampling Location	Non Detect?	Detected Level	Units	CCR Units
TTHM	11/19/2009	GENERIC SAMPLING POI	Y	0.000		0.000

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.

RTCR Sampling History
PWS Number: ID7260032
PWS Name: RIGBY CITY OF
Total Records: 0

Only report if your water system was required to comply with one or more Revised Total Coliform Rule (RTCR) Level 1 and/or Level 2 Assessments during the 2017 calendar year.

Required Language: If your water system was required to conduct an RTCR Level 1 or Level 2 Assessment (numbers I-III below), the associated information must be reported in the CCR in accordance with IDAPA 58.01.08.151.

- I. If your water system was required to conduct a Level 1 or 2 assessment **not** due to an *E. coli* MCL violation, go to section I below.
- II. If your water system was required to conduct a Level 2 assessment **due** to an *E. coli* MCL violation, go to section II below.
- III. If your water system detected *E. coli* and **did not** violate the *E. coli* MCL, go to section III below.

I. If your water system was required to conduct a Level 1 or 2 assessment not due to an *E. coli* MCL violation, you must include in the report adverse health affect information and additional information regarding the number of assessments required, the number of assessments completed, the number of corrective actions required and the number of corrective actions completed.

(A) Adverse Health Effects Required Text: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

(B) Additional Information Required:

- a. During the past year we were required to conduct [INSERT NUMBER OF LEVEL 1 ASSESSMENTS] Level 1 assessment(s). [INSERT NUMBER OF LEVEL 1 ASSESSMENTS] Level 1 assessment(s) were completed. In addition, we were required to take [INSERT NUMBER OF CORRECTIVE ACTIONS] corrective actions and we completed [INSERT NUMBER OF CORRECTIVE ACTIONS] of these actions.
- b. During the past year [INSERT NUMBER OF LEVEL 2 ASSESSMENTS] Level 2 assessments were required to be completed for our water system. [INSERT NUMBER OF LEVEL 2 ASSESSMENTS] Level 2 assessments were completed. In addition, we were required to take [INSERT NUMBER OF CORRECTIVE ACTIONS] corrective actions and we completed [INSERT NUMBER OF CORRECTIVE ACTIONS] of these actions.
- c. Any system that has failed to complete all the required assessments or correct all identified sanitary defects, is in violation of the treatment technique requirement and must also include one or both of the following statements, as appropriate:
 - i. During the past year we failed to conduct all of the required assessment(s).
 - ii. During the past year we failed to correct all identified defects that were found during the assessment.

II. If your water system was required to conduct a Level 2 assessment due to an *E. coli* MCL violation, you must include in the report adverse health affect information and additional information regarding the number of assessments required, the number of assessments completed, the number of corrective actions required and the number of corrective actions completed.

(A) Adverse Health Effects Required Text: *E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

(B) Additional Information Required:

a. We were required to complete a Level 2 assessment because we found *E. coli* in our water system. In addition, we were required to take [INSERT NUMBER OF CORRECTIVE ACTIONS] corrective actions and we completed [INSERT NUMBER OF CORRECTIVE ACTIONS] of these actions.

b. Any system that has failed to complete the required assessment or correct all identified sanitary defects, is in violation of the treatment technique requirement and must also include one or both of the following statements, as appropriate:

i. We failed to conduct the required assessment.

ii. We failed to correct all sanitary defects that were identified during the assessment that we conducted.

c. Any system that violated the *E. coli* MCL, the system must include, in addition to the required adverse health effects text [see II.(A) above], one or more of the following statements to describe any noncompliance, as applicable:

i. We had an *E. coli*-positive repeat sample following a total coliform-positive routine sample.

ii. We had a total coliform-positive repeat sample following an *E. coli*-positive routine sample.

iii. We failed to take all required repeat samples following an *E. coli*-positive routine sample.

iv. We failed to test for *E. coli* when any repeat sample tests positive for total coliform.

III. If your water system detected *E. coli* and did not violate the *E. coli* MCL, the system may include, in addition to the required adverse health effects text [See II.(A) above], a statement that explains that although *E. coli* water detected, your system was not in violation of the *E. coli* MCL.

No results were found for the RTCR Sampling History Report.

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.

Chlorine Maximum Residual Disinfectant Level Sampling History

PWS Number: ID7260032
PWS Name: RIGBY CITY OF
Total Records: 0

Sampling history is only listed for systems which are practicing chlorination on a full-time basis.

Please include in your CCR the highest chlorine residual level detected during the previous calendar year (2022) by your system, as well as the average of all residuals collected during 2022.

Required Language. If the system exceeds the chlorine MCL (maximum contaminant level) value, the system must show the potential health effects of the contaminant. To report this information, go to **Appendix A of the CCR template**, find the contaminant, and copy the information from the *"Health Effects Language"* column and place it in your CCR.

No results were found for the Chlorine Maximum Residual Disinfectant Level Sampling History Report.

Note: Please notify your regional DEQ office if you find discrepancies in your sampling or violation histories. DEQ will correct the errors in the agency's database.